

- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- RAA - Running Annual Average

## GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. George Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## CONTAMINANT VIOLATIONS

None

## ADDITIONAL HEALTH INFORMATION

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

## OTHER VIOLATIONS

None

## SOURCE WATER ASSESSMENT INFORMATION

The George water supply obtains its water from the alluvial aquifer. The alluvial aquifer was determined to be highly susceptible to contamination because the characteristics of the aquifer and overlying materials allow contaminants to move through the aquifer fairly quickly. The wells will be most susceptible to activities such as dry cleaners, gas stations, industrial sites, and municipal wastewater dischargers. A detailed evaluation of your source water was completed by the IDNR, and is available from City of George at 712-475-3612.

## OTHER INFORMATION

Our water utility is making every effort to protect the water system from potential security threats. You, as customers, can also help. If you see any suspicious activity near the water tower, treatment plant, wells or fire hydrants, please contact us at [Insert water system phone number] or the local police/sheriff department. We appreciate your assistance in protecting the water system.

## CONTACT INFORMATION

For questions regarding this information, please contact Todd Klein at 712-348-3014 during the following hours: 8 AM to 4 PM of the City Clerk at 712-475-3612.

Decisions regarding the water system are made at the City Council meetings held on 2<sup>nd</sup> Wednesday of every month at 7:00 p.m. at 120 South Main and are open to the public.

Please note: This report will not be mailed to individual customers.